

Spokane Regional Health District
1101 W. College Ave
Spokane, WA 99201

Addendum No. 1 to All Offerors

Reference – Request for Proposal:	RFP 150-165-001
Commodity:	Roofing on all four (4) balconies and Satellite removal/disposal
Date:	May 28, 2021
Proposal Due:	June 4, 2021

This Addendum 1 to the RFP addresses changes and questions received. The Proposer shall indicate receipt of this Addendum and any previously issued Addenda by signing the form(s) for inclusion with the proposal responses.

1. Could I please get an engineer's estimate or cost range for this project?

The cost range for this project is \$75,000.

2. Storage of materials at SRHD.

To help secure material costs for this project, SRHD will provide an area for storage so that materials for the roofing can be purchased at the time of the contract signing and stored until the project start date.

3. Asbestos Testing

SRHD has contracted with IRS Environmental to conduct an asbestos testing on the balcony roof. At this time, the South balcony has tested positive, the remaining balconies came back as non-detect samples. The balcony roofs were installed at the same time, with the same materials, so the possibilities of all four balconies testing positive with asbestos are very high. Attached is a copy of the report for review.